

DECLARATION OF PERFORMANCE

According to Construction Products Regulation EU N° 305/2011

N° 011-01

1. Unique Product identification code:

PWR-01

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

Art.No.	Type	Description
20081370	EPM 6-30-EN54	Emergency Power Supply Manager according EN 54-4, 6 Outputs with 30A each, 1438/CPD/0322

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

EN 54-4:1997+AC:1999+A1:2002+A2:2006

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

ic audio GmbH
Boehringerstraße 14a
D-68307 Mannheim

Germany

Fon: + 49 (0) 6 21 / 77 09 6 - 0
Fax: + 49 (0) 6 21 / 77 09 6 - 26

E-Mail: info@ic-audio.com

www.ic-audio.com

05.10.2011



Heinz Pfannenschmidt
Managing Director

DECLARATION OF PERFORMANCE

According to Construction Products Regulation EU N° 305/2011

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

Not applicable

6. System or systems of assessment and verification of constancy of performance of the construction product:

System 1

7. Declaration of performance concerning a construction product covered by the harmonized standard:

Jednostka Certyfikująca | Certification Department
Centrum Naukowo-Badawcze Ochrony Przeciwpowodziowej
Państwowy Instytut Badawczy (CNBOP-PIB)
ul. Nadwiślańska 213, 05-420 Józefów, Poland
tel: (+48) 22 76 93 319, (+48) 22 76 93 345
fax: (+48) 22 76 93 356

performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control and issued the

EC Certificate of conformity: 1438/CPD/0322 

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable, see item 7

9. Declared performance:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in point 3 above have been determined as described in the hEN mentioned in the table below.

05.10.2011



Heinz Pfannenschmidt
Managing Director

DECLARATION OF PERFORMANCE

According to Construction Products Regulation EU N° 305/2011

Essential characteristics	Performance	Harmonized technical specification EN 54-4:1997+AC:1999+A1:2002+A2:2006
Performance of power Supply		
General requirements	passed	Fire detection and fire alarm systems – Part 4: Power Supply Equipment, Section 4
Functions	passed	Fire detection and fire alarm systems – Part 4: Power Supply Equipment, Section 5
Materials, design and manufacture	passed	Fire detection and fire alarm systems – Part 4: Power Supply Equipment, Section 6
Operational reliability		
General requirements	passed	Fire detection and fire alarm systems – Part 4: Power Supply Equipment, Section 4
Functions	passed	Fire detection and fire alarm systems – Part 4: Power Supply Equipment, Section 5
Materials, design and manufacture	passed	Fire detection and fire alarm systems – Part 4: Power Supply Equipment, Section 6
Documentation	passed	Fire detection and fire alarm systems – Part 4: Power Supply Equipment, Section 7
Durability of operational reliability, temperature resistance		
Cold (operational)	passed	Fire detection and fire alarm systems – Part 4: Power Supply Equipment, Section 9.5
Durability of operational reliability, vibration resistance		
Impact (operational)	passed	Fire detection and fire alarm systems – Part 4: Power Supply Equipment, Section 9.7
Vibration, sinusoidal (operational)	passed	Fire detection and fire alarm systems – Part 4: Power Supply Equipment, Section 9.8
Vibration, sinusoidal (endurance)	passed	Fire detection and fire alarm systems – Part 4: Power Supply Equipment, Section 9.15
Durability of operational reliability, electrical stability		
Electromagnetic compability (EMC), immunity test (operational)	passed	Fire detection and fire alarm systems – Part 4: Power Supply Equipment, Section 9.9
Durability of operational reliability, humidity resistance		
Damp heat, steady state (operational)	passed	Fire detection and fire alarm systems – Part 4: Power Supply Equipment, Section 9.6
Damp heat, steady state (endurance)	passed	Fire detection and fire alarm systems – Part 4: Power Supply Equipment, Section 9.14

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

05.10.2011



Heinz Pfannenschmidt
Managing Director