

DA-S 20-130/T-EN54

Sound projector for Voice Alarm, 20W power, certified
EN 54-24



Technical Data

Colour	RAL 9010
Dimensions	138x163 mm
Dispersion -6dB, 500Hz	360° v/h
Dispersion -6dB, 1KHz	210° v/h
Dispersion -6dB, 2KHz	105° v/h
Dispersion -6dB, 4KHz	55° v/h
Sensitivity EN54-24, 1W/1m	92,3 dB
Sensitivity EN54-24, 1W/4m	80,3 dB
Frequency Range	800 - 16.700 Hz
Frequency Response	150 - 20.000 Hz
SPL IEC268-5, 1W/1m	92,0 dB
SPL EN54-24, Pmax/4m	93,0 dB
Power	20/15/10/5 W



DA-S 20-130/T-EN54

Mounting Instruction

- 1. Mount the U-bracket on the ceiling with the appropriate screws for the surface.
- 2. If necessary, remove the speaker enclosure from the U-bracket.
- 3. Mount the cable junction box on the wall or ceiling with screws suitable for the surface.
- 4. Connect the loudspeaker cable to the terminals 100V and COM.
If necessary, select a different power tapping.
- 5. Close the cover of the junction box.

Power Tappings

Black	Red	Yellow	Blue	Green
COM	20	15	10	5

TO MAKE PEOPLE LISTEN



CE-Symbol according to 93/68EWG
Measurements according to DIN IEC 268-5
RoHS compliant (2011/65/EU)
CPR compliance according 305/2011/EU

Loudspeaker for voice alarm systems for fire
detection and fire alarm systems for buildings
ic audio GmbH, Boehringerstraße 14A
68307 Mannheim, Germany

EN54-24:2008
Ref. Nr.:002-13
ID-Code:SAA-LS02
1438-CPR-1000