

DL 06-130/T-EN54

Ceiling speaker for Voice Alarm, power 6W, certified
EN 54-24



Technical Data

Colour	RAL 9010
Dimensions	180x110 mm
Ceiling Cut-out	167 mm
Dispersion -6dB, 500Hz	h/v 180°
Dispersion -6dB, 1KHz	h/v 180°
Dispersion -6dB, 2KHz	h/v 120°
Dispersion -6dB, 4KHz	h/v 65°
Sensitivity EN54-24, 1W/1m	92,0 dB
Sensitivity EN54-24, 1W/4m	80,0 dB
Frequency Range	350 - 13.800 Hz
Frequency Response	84 - 16.300 Hz
SPL IEC268-5, 1W/1m	92,0 dB
SPL EN54-24, Pmax/4m	88,0 dB
Power	6/3/1,5 W




DL 06-130/T-EN54

Mounting Instruction

1. Create the necessary ceiling cut-out and check the installation depth.
2. Fix the outer ring in the ceiling.
3. Attach the fire dome to the ring in the ceiling.
4. Lift the three springs on the spring slots on the ring, and turn them to the side. Guide the connection cable through the opening.
5. Position the fire dome below the notches and then push it upwards. Turn the springs back into the spring slots (starting position).
6. Connect the loudspeaker cable to the 100V and COM terminals.
If necessary, select a different power tapping.
7. Use the enclosed mounting hook to place the grille in the speaker ring and turn it clockwise.

Please note: Do not insert the hook into the grille more than 5mm from the outer ring to avoid damage. We recommend loosening the cable lug with a flat-blade screwdriver when changing the cable to a different power tapping.




CE-Symbol according to 93/68EWG
Measurements according to DIN IEC 268-5
RoHS compliant (2011/65/EU)
CPR compliance according 305/2011/EU

Loudspeaker for voice alarm systems for fire
detection and fire alarm systems for buildings
ic audio GmbH, Boehringerstraße 14A
68307 Mannheim, Germany

EN54-24:2008
Ref. Nr.: 010-14
ID-Code: SAA-LS01
1438-CPR-1119

DL 06-130/T-EN54



CE-Symbol according to 93/68EWG
Measurements according to DIN IEC 268-5
RoHS compliant (2011/65/EU)
CPR compliance according 305/2011/EU

Loudspeaker for voice alarm systems for fire
detection and fire alarm systems for buildings
ic audio GmbH, Boehringerstraße 14A
68307 Mannheim, Germany

EN54-24:2008
Ref. Nr.: 010-14
ID-Code: SAA-LS01
1438-CPR-1119

TO MAKE PEOPLE LISTEN