

TS-C30-700/T-EN54

Sound column for Voice Alarm, 30W power, certified
EN 54-24



Technical Data

Colour	RAL 9006
Dimensions	700x100x92 mm
Dispersion -6dB, 500Hz	h=360°, v=114°
Dispersion -6dB, 1KHz	h=190°, v=50°
Dispersion -6dB, 2KHz	h=160°, v=26°
Dispersion -6dB, 4KHz	h=85°, v=13°
Sensitivity EN54-24, 1W/1m	93,0 dB
Sensitivity EN54-24, 1W/4m	81,0 dB
Frequency Range	230 - 16.500 Hz
Frequency Response	137 - 23.500 Hz
SPL IEC268-5, 1W/1m	93,0 dB
SPL EN54-24, Pmax/4m	96,7 dB
Power	30/15/7.5 W



TS-C30-700/T-EN54

Mounting Instruction

Use a screwdriver for recessed head screws, Bit PH2.

- 1. Mount the swivel bracket on the wall.
- 2. Fit the sound column on the swivel bracket.
- 3. Unscrew the base of the sound column.
- 4. Insert the incoming cable through the cable gland and connect it to the terminal.
- 5. Screw the base back onto the sound column.

Power Tappings

Black	Brown	Red	White
COM	30	15	7.5



CE-Symbol according to 93/68EWG
Measurements according to DIN IEC 268-5
RoHS compliant (2011/65/EU)
CPR compliance according 305/2011/EU

Loudspeaker for voice alarm systems for fire
detection and fire alarm systems for buildings
ic audio GmbH, Boehringerstraße 14A
68307 Mannheim, Germany

EN54-24:2008
Ref. Nr.:006-13
ID-Code:SAA-
LS06
1438/CPD/0315

TO MAKE PEOPLE LISTEN