TS-C 30-700/T-EN54

Sound column for Voice Alarm, 30W power, certified EN 54-24



Technical Data

Colour	RAL 9006
Dimensions	700x100x92 mm
Dispersion -6dB, 500Hz	360°/114° h/v
Dispersion -6dB, 1KHz	190°/50° h/v
Dispersion -6dB, 2KHz	160°/26° h/v
Dispersion -6dB, 4KHz	85°/13° h/v
Frequency Range	230 - 16.500 Hz
Frequency Response	137 - 23.500 Hz
Power	30/15/7.5 W

TO MAKE PEOPLE LISTEN

Copyright ©2026 ic audio GmbH. All rights reserved. Date: 2026-10-07

TS-C 30-700/T-EN54

4 260590 180506

Mounting Instruction

Use a screwdriver for recessed head screws, Bit PH2.

1. Mount the swivel bracket on the wall.
2. Fit the sound column on the swivel bracket.
3. Unscrew the base of the sound column.
4. Insert the incoming cable through the cable gland and connect it to the terminal.
5. Screw the base back onto the sound column.

Power Tappings

Black	Brown	Red	White
COM	30	15	7,5

CE
13

CE-Symbol according to 93/68EWG
Measurements according to DIN IEC 268-5
RoHS compliant (2011/65/EU)
CPR compliance according 305/2011/EU

Loudspeaker for voice alarm systems for fire detection and fire alarm systems for buildings
ic audio GmbH, Boehringerstraße 14A
68307 Mannheim, Germany

EN54-24:2008
Ref. Nr.:058-26
ID-Code:SAA-LS68
1438/CPD/0315

TO MAKE PEOPLE LISTEN

Copyright ©2026 ic audio GmbH. All rights reserved. Date: 2026-10-07