TS-C 50-1000/T-EN54

Sound column for Voice Alarm, 50W power, certified EN 54-24



Mechanical Data

Colour	RAL 9006
Dimensions	971x100x92 mm
Weight (net)	5,20 kg
Power	50/30/15/7,5 W
Connector	2-pin ceramic block
Terminal Diameter	4,0 mm
Maximum Cable Passage	12,5 mm^2
Mounting	Swivel bracket

TO MAKE PEOPLE LISTEN

Copyright ©2026 ic audio GmbH. All rights reserved. Date: 2026-10-08

TS-C 50-1000/T-EN54

Mounting Instruction

Use a screwdriver for recessed head screws, Bit PH2.

1. Mount the swivel bracket on the wall.
2. Fit the sound column on the swivel bracket.
3. Unscrew the base of the sound column.
4. Insert the incoming cable through the cable gland and connect it to the terminal.
5. Screw the base back onto the sound column.

Power Tappings

Black	Brown	Red	White	Green
COM	50	30	15	7,5

CE
13

CE-Symbol according to 93/68EWG
Measurements according to DIN IEC 268-5
RoHS compliant (2011/65/EU)
CPR compliance according 305/2011/EU

Loudspeaker for voice alarm systems for fire detection and fire alarm systems for buildings
ic audio GmbH, Boehringerstraße 14A
68307 Mannheim, Germany

EN54-24:2008
Ref. Nr.:059-26
ID-Code:SAA-LS69
1438/CPD/0315

TO MAKE PEOPLE LISTEN

Copyright ©2026 ic audio GmbH. All rights reserved. Date: 2026-10-08