



DA-P 10-130/T-EN54

Sound projector for Voice Alarm, 10W power, certified EN 54-24

Technical Data

Colour	RAL 9016
Dimensions	138x204 mm
Dispersion -6dB, 500Hz	360°
Dispersion -6dB, 1KHz	230°
Dispersion -6dB, 2KHz	110°
Dispersion -6dB, 4KHz	58°
Sensitivity EN54-24, 1W/4m	75,0 dB
Frequency Range	150 - 20.000 Hz
Frequency Response	120 - 21.000 Hz
SPL IEC268-5, 1W/1m	87,0 dB
SPL EN54-24, Pmax/4m	86,0 dB
Power	10/5/2,5/1,25 W



DA-P 10-130/T-EN54

Mounting Instruction

- 1. Mount the U-bracket on the ceiling with the appropriate screws for the surface.
- 2. If necessary, remove the speaker enclosure from the U-bracket.
- 3. Mount the cable junction box on the wall or ceiling with screws suitable for the surface.
- 4. Connect the loudspeaker cable to the terminals 100V and COM.
If necessary, select a different power tapping.
- 5. Close the cover of the junction box.

Power Tappings

Black	Red	Yellow	Blue	Green
COM	10	5	2,5	1,25

TO MAKE PEOPLE LISTEN



CE-Symbol according to 93/68EWG
Measurements according to DIN IEC 268-5
RoHS compliant (2011/65/EU)
CPR compliance according 305/2011/EU

Loudspeaker for voice alarm systems for fire
detection and fire alarm systems for buildings
ic audio GmbH, Boehringerstraße 14A
68307 Mannheim, Germany

EN54-24:2008
Ref. Nr.:021-18
ID-Code:SAA-LS21
1438-CPR-1094