

DK15/T-EN54-PG

Horn speaker for Voice Alarm, 15W power, certified EN 54-24



Technical Data

Colour	RAL 7035
Dimensions	209x321 mm
Dispersion -6dB, 500Hz	h/v 360°
Dispersion -6dB, 1KHz	h/v 110°
Dispersion -6dB, 2KHz	h/v 70°
Dispersion -6dB, 4KHz	h/v 40°
Sensitivity EN54-24, 1W/1m	95,3 dB
Sensitivity EN54-24, 1W/4m	83,0 dB
Frequency Range	677 - 5.400 Hz
Frequency Response	300 - 13.800 Hz
SPL IEC268-5, 1W/1m	95,0 dB
SPL EN54-24, Pmax/4m	93,0 dB
Power	15/7,5/3,75/1,9 (20) W



DK15/T-EN54-PG

Mounting Instruction

1. Mount the U-bracket on the ceiling with the appropriate screws for the surface.
2. If necessary, remove the speaker enclosure from the U-bracket.
3. Insert the loudspeaker cable through the cable entry of the previously removed rear wall of the housing.
4. Connect the loudspeaker cable to the terminals 100V and COM.
If necessary, select a different power tapping.
5. Carefully reinsert the back panel into the housing.

EQ Settings

EQ Setting Frequency [Hz]	Relative level to 1000 Hz [dB]	EQ Setting Frequency [Hz]	Relative level to 1000 Hz [dB]	EQ Setting Frequency [Hz]	Relative level to 1000 Hz [dB]	EQ Setting Frequency [Hz]	Relative level to 1000 Hz [dB]
20	0	80	0	315	+12	1250	0
25	0	100	-12	400	+12	1600	-4
31,5	0	125	-12	500	+8	2000	0
40	0	160	-8	630	+4	2500	0
50	0	200	0	800	-2	3150	0
63	0	250	+6	1000	0	4000	+8
80	0	315	+12	1250	0	5000	+12
100	-12	400	+12	1600	-4	6300	+12



CE-Symbol according to 93/68EWG
 Measurements according to DIN IEC 268-5
 RoHS compliant (2011/65/EU)
 CPR compliance according 305/2011/EU

Loudspeaker for voice alarm systems for fire
 detection and fire alarm systems for buildings
 ic audio GmbH, Boehringerstraße 14A
 D-68307 Mannheim, Germany

EN54-24:2008
 Ref. Nr.:003-13
 ID-Code:SAA-LS03
 1438-CPR-1177

TO MAKE PEOPLE LISTEN